

**TB10-111R**

# **TECHNICAL SERVICES BULLETIN**

---

**To: Residential Distributors and Dealers**  
**From: Technical Support**  
**Date: February 04, 2010**  
**Re: Demand Defrost Board and Head Pressure Switch in Q5RF Units**

NORDYNE is announcing a change to the Demand Defrost board (920268) from the Adaptive Defrost Board (920388) in the Q5RF models. Units produced starting the first week of February and starting with the Serial number Q5RF100200185 will contain this change. Units will continue to be produced with the Demand Defrost Boards until further notice.

In addition to the defrost board change, NORDYNE is also changing the high pressure switch to a 632473 which is rated at 650 psig starting with the same serial number as above. This will be a permanent change.

If you have any questions please call **1-800-422-4328 ext. 2**

Thank You  
NORDYNE Technical Service